



BLDG # 6 LIGHTING PLAN.

SCALE 1/4" = 1-0"

LEGEND TO SYMBOLS

- EXISTING CEIL/WALL FIXTURE
- EXISTING CEILING FIXTURE - TO BE REMOVED
- NEW FLUORESCENT FIXTURE
- RUN HOME TO CIRCUIT BREAKER PANEL
- SWITCH LEG

LIGHTING FIXTURE SCHEDULE

MANUFACTURER	STOCK #	LAMP	MOUNT
A	LITECONTROL # 5024 RS 6150	F40CW3	SURFACE
B	LITECONTROL # 5048 RS 6150	F40CW3	SURFACE

NOTES

1. ALL WIRING IN ACCORDANCE WITH NATIONAL ELEC. CODE.
2. REMOVE EXISTING FIXTURES IN RELIGHTED ROOMS AND REPLACE ANY MISSING OR DAMAGED CEILING TILES WITH NEW MATCHING TILES.
3. REMOVE ANY EXCESS WIRING OR BOXES AS A RESULT OF THE NEW LIGHTING.
4. INSTALL TWO NEW DUPLEX RECEPTACLES IN PRINCIPAL OFFICE AND CORRIDOR TO MATCH OTHERS IN BUILDING.
5. ALL WIRING SHALL BE #12 TH OR EQUAL AND CONCEALED.

THE TOWN OF NORTH SMITHFIELD
DR. HARRY L. HALLIWELL SCHOOL

ELECTRICAL REVISIONS
SCALE 1/4" = 1-0"

DEC 26 1962

PREPARED BY
POWER SALES DEPT. B.V.G.E CO
ROBERT J. MCCORMICK, ENGINEER